



Helifuel

HELIFUEL™ SYSTEM

LOGG FOR DIFFERANSE TRYKK - SEPARATOR

JANUAR - DESEMBER

Doc. no.: SS-KUN-012

Page: 2 av 2

Date: 27.02.2009

Created by: BK

PSI	BAR	MAKSIMUM DIFFERANSE TRYKK: 15 PSI																										
16	1.0																											
14	0.9																											
12	0.8																											
10	0.6																											
8	0.5																											
6	0.4																											
4	0.2																											
2	0.1																											
	UKE	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	

Helifuel AS
 Hanaleite 1
 N-5550 Sveio, Norway

Tel.: +47 53 74 77 00
 Fax: +47 53 74 77 09
 helifuel@helifuel.com